COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOR CO		
1	Manufacturer: Atlas Copco		
2	Model Number: ZT 250 VSD-150	Date:	12-17-2018
	x Air-cooled Water-cooled	Туре:	Screw
	Oil-injected x Oil-free	# of Stages:	2
3	Rated Operating Pressure	130	psig ^b
4	Drive Motor Nominal Rating	335	hp
5	Drive Motor Nominal Efficiency	95.3	percent
6	Fan Motor Nominal Rating (if applicable)	5.4	hp
7	Fan Motor Nominal Efficiency	Fan Motor Nominal Efficiency 81.3	
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
	290.2 Ma	x 1352	21.5
Out	260.6	1219	21.4
8*	232.9	1087	21.4
	207.1	954	21.7
	182.2 M	n 822	22.2
9*	Total Package Input Power at Zero Flow ^{c, d}	34.1	kW
10	35.0		
	25.0 (KW/100 A CFM) 20.0 20.0		
	15.0		
	10.0 0 100 200 300 400 500 600 70 Capacity Note: Graph is only a visual repr Note: Y-Axis Scale, 10 to 35, + 5kW/10 X-Axis Scale, 0 to 25%	(ACFM) sentation of the data in Section 8 Dacfm increments if necessary above	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ /min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8]
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

10/11 R7 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.