COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOR C			
1	Manufacturer: Atlas Copco			
2	Model Number: ZT 250 VSD-125		Date:	12-17-2018
	x Air-cooled Water-cooled	Type:	Screw	
	Oil-injected x Oil-free		# of Stages:	2
3	Rated Operating Pressure	125	psig ^b	
4	Drive Motor Nominal Rating	335	hp	
5	Drive Motor Nominal Efficiency		95.3	percent
6	Fan Motor Nominal Rating (if applicable)	5.4	hp	
7	Fan Motor Nominal Efficiency	81.3	percent	
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
	288.3	Max	1367	21.1
O.I.	240.6		1151	20.9
8*	197.9		935	21.2
	158.1		719	22.0
	120.2	Min	503	23.9
9*	Total Package Input Power at Zero Flow ^{c, d}		21.3	kW
10	Note: Graph is only a visual r Note: Y-Axis Scale, 10 to 35, + 5kW	city (AC epresen	CFM) tation of the data in Section 8	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



ame Flow Rate cified conditions	Volume Flow Rate Specific Energy Consumption		No Load / Zero Flow Power
<u>ft3 / min</u>	%	%	
Below 15	+/- 7	+/- 8	
15 to 50	+/- 6	+/- 7	+/- 10%
50 to 500	+/- 5	+/- 6	
Above 500	+/- 4	+/- 5	
	### First State	tified conditions Volume Flow Rate ft3 / min % Below 15 +/- 7 15 to 50 +/- 6 50 to 500 +/- 5	tified conditions Volume Flow Rate Consumption ft3 / min % % Below 15 +/- 7 +/- 8 15 to 50 +/- 6 +/- 7 50 to 500 +/- 5 +/- 6

ROT 031

10/11 R7 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.