	Federal Unifor	m Test Method fo		Compressors Not Aj	oplicable
			npressor: Fixed		
	1	MODEL DATA -	FOR COMPR	ESSED AIR	
1	Manufacturer:	Atlas Copco			
	Model Number	ZT 90-	7.25	Date:	01-04-2021
2	Air-cooled	Water-co	ooled	Type:	Screw
	Oil-injected	✓ Oil-free		# of Stages:	2
3*	Rated Capacity at Full Load Operating Pressure*(a,e)		5	553.6	(acfm) *(a,e)
4	Full Load Operating Pressure*(b)			102.0	psig*(b)
5	Maximum Full Flow Operating Pressure*(c)		re*(c)	105.2	psig*(c)
6	Drive Motor Nominal Rating			120.7	hp
7	Drive Motor Nominal Efficiency			95.0	percent
8	Fan Motor Nominal Rating (if applicable)		ble)	5.4	hp
9	Fan Motor Nominal Efficiency			81.3	percent
10*	Total Package Input Power at Zero Flow*(e)		ow*(e)	31.2	kW*(e)
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)			116.2	kW*(d)
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e)			21.0	kW/100 cfm*(e)
	*For models that are tested in	the CAGI Performance V	erification Program, th	ese items are verified by pro	gram administrator
Notes:	Consult CAGI website for a list of participants in the third party verification program: www.cagi.org a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.				
Member	 b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet. c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, 				
AGI sed Air & Gas Institute	manufacturer may sd. Total package inpute Tolerance is specific	ate "not significant" or "0	" on the test report. ted operating points wi as shown in table below	ll vary with control strategy.	
	Volume Flow Rate			Specific Energy	
	at specified	conditions <u>ft3 / min</u>	Volume Flow Ra %	te Consumption %	Flow Power
	<u>m3 / min</u> Below 0.5	Below 15		+/- 8	
	0.5 to 1.5			+/- 7	+/- 10
	1.5 to 15 50 to 500 +		+/- 5	+/- 5 +/- 6	
030.2			+/- 4	+/- 5	