| | Federal Uniform | n Test Method fo Rotary Con | | Air Compressors Not A ixed Speed | Applicable |
|---------------------------------------|---|---|---|-------------------------------------|----------------------|
| | ľ | MODEL DATA - | _ | - | |
| 1 | Manufacturer: | Atlas Copco | | | |
| | Model Number: | ZT 75 ST | D-10.4 | Date | 07-22-2021 |
| 2 | Air-cooled | Water-co | ooled | Type | Screw |
| | Oil-injected | ✔ Oil-free | | # of Stages: | 2 |
| 3* | Rated Capacity at Full Load Operating Pressure*(a,e) | | 5 | 417.4 | (acfm) *(a,e) |
| 4 | Full Load Operating Pressure*(b) | | | 150.0 | psig*(b) |
| 5 | Maximum Full Flow Operating Pressure*(c) | | ure*(c) | 150.8 | psig*(c) |
| 6 | Drive Motor Nominal Rating | | | 100.6 | hp |
| 7 | Drive Motor Nominal Efficiency | | | 96.2 | percent |
| 8 | Fan Motor Nominal Rating (if applicable) | | ble) | 0.0 | hp |
| 9 | Fan Motor Nominal Efficiency | | | 91.7 | percent |
| 10* | Total Package Input | al Package Input Power at Zero Flow*(e) | | 22.9 | kW*(e) |
| 11 | Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d) | | | 95.7 | kW*(d) |
| 12* | Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e) | | | 22.9 | kW/100 cfm*(e) |
| | *For models that are tested in t | he CAGI Performance V | verification Progr | am, these items are verified by p | rogram administrator |
| Notes: | Consult CAGI website for a list of participants in the third party verification program: www.cagi.c a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions. | | | | |
| Member | b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet. | | | | |
| AGI sed Air & Gas Institute | manufacturer may stad. Total package input pe Tolerance is specified | te "not significant" or "C bower at other than report I in ISO 1217, Annex E, |)" on the test reported operating point as shown in table | nts will vary with control strateg | |
| | Volume Flow Rate | | | Specific Energ | gy No Load / Zero |
| | at specified conditions | | Volume Fl | 1 | n Flow Power |
| | <u>m3 / min</u> Below 0.5 | <u>ft3 / min</u> Below 15 | % | | |
| | 0.5 to 1.5 15 to 50 + 1.5 to 15 50 to 500 + | | +/- 6 | | +/- 10 |
| | | | +/- | | |
| 030.2 | | | +/- | 4 +/- 5 | |