	Rot	COMPRESSOR DA Test Method for Certain tary Compressor: Variab	Air Compressors Not A le Frequency Drive	pplicable
		ODEL DATA - FOR CO	MPRESSED AIR	
1	Manufacturer:	Atlas Copco		
2	Model Number: ZT 75 VSD+		Date:	06-23-2021
	✓ Air-cooled Water-cooled		Type:	Screw
	Lubricated	✓ Oil-free	# of Stages:	2
3	Full Load Operating Pressure*(b)		150.0	psig*(b)
4	Drive Motor Nominal Rating		53.6 & 53.6	hp
5	Drive Motor Nominal Efficiency		97.0 & 97.0	percent
6	Fan Motor Nominal Rating (if applicable)		11.8	hp
7	Fan Motor Nominal Efficiency		69.9	percent
8*	Input Power (kW)		Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	85.3 Max		384.1	22.2
	75.4		328.5	23.0
	65.5		272.8	24.0
	55.5		217.2	25.6
9*	45.8		161.5	28.3
9*	Total Package Input	Power at Zero Flow*(c,d)	0.0	kW
10	Specific Power (kW/100ACFM) 12 12			
	10		200 300	400
*5			pacity (ACFM)	1
Notes: Member	Consult CAGI website for a a. Measured at the discha ISO 1217, Annex E; ac b. The operating pressure c. No Load Power. In ac manufacturer may state d. Tolerance is specified	GI Performance Verification Pr list of participants in the third pa rge terminal point of the compressor packa fm is actual cubic feet per minute at inlet c at which the Capacity and Electrical Cons cordance with ISO 1217, Annex E, if meas e "not significant" or "0" on the test report. in ISO 1217, Annex E, as shown in table bo wer" and "energy" are synonymous for pur	arty verification program: ge in accordance with onditions. umption were measured for this data sheet urement of no load power equals less than clow:	www.cagi.org
Compressed Air & Gas Institut	Volume Flow Rate		Specific Energ	
	<u>at specified</u> <u>m3 / min</u>	<u>ft3 / min</u>	ne Flow Rate Consumption % %	Flow Power
	1			
	Below 0.5	Below 15	+/- 7 +/- 8	
	Below 0.5 0.5 to 1.5 1.5 to 15	Below 15 15 to 50 50 to 500	+/- 7 +/- 8 +/- 6 +/- 7 +/- 5 +/- 6	+/- 10