COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: Atlas Copco		
2	Model Number: ZT 90 VSD-8.6	Date:	01-05-2021
	✓ Air-cooled	Туре:	Screw
	☐ Lubricated ☑ Oil-free	# of Stages:	2
3	Full Load Operating Pressure*(b)	124.0	psig*(b)
4	Drive Motor Nominal Rating	120.7	hp
5	Drive Motor Nomnial Efficiency	93.5	percent
6	Fan Motor Nominal Rating (if applicable)	5.4	hp
7	Fan Motor Nominal Efficiency	81.3	percent
8*	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	121.1 Max	499.4	24.2
	100.2	413.9	24.2
	82.1	328.3	25.0
	65.6	242.8	27.0
	50.1 Min	157.3	31.9
9*	Total Package Input Power at Zero Flow*(c,d)	15.3	kW
10	Specific Power (KW/100ACFM) 10 0 100 200 Cap	300 400 Dacity (ACFM)	500 600

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org


Notes:

Member

Compressed Air & Gas Institute

- Measured at the discharge terminal point of the compressor package in accordance with
- ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document



ROT 031.2 12/19 R3