COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR 1 Manufacturer: Atlas Copco 01-05-2024 ZT 200-10.4 Date: Model Number: ✓ Air-cooled Water-cooled 2 Screw Type: Oil-injected ✓ Oil-free # of Stages: 2 Rated Capacity at Full Load Operating 3* 974.3 (acfm) *(a,e)Pressure*(a,e) 4 Full Load Operating Pressure*(b) 150.0 psig*(b) 5 Maximum Full Flow Operating Pressure*(c) 150.8 psig*(c) 6 248.1 Drive Motor Nominal Rating hp 7 Drive Motor Nominal Efficiency 96.5 percent 8 10.7 Fan Motor Nominal Rating (if applicable) hp 9 Fan Motor Nominal Efficiency 81.3 percent 10* Total Package Input Power at Zero Flow*(e) 39.3 kW*(e) Total Package Input Power at Rated Capacity 211.4 kW*(d)11 and Full Load Operating Pressure*(d) Specific Package Input Power at Rated Capacity 12* 21.7 kW/100 cfm*(e)

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Notes:

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- Membe
- The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.



- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- . Total package input power at other than reported operating points will vary with control strategy.
- e Tolerance is specified in ISO 1217, Annex E, as shown in table below:

and Full Load Operating Pressure*(e)

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate			Specific Energy	No Load / Zero
at specified conditions		Volume Flow Rate	Consumption	Flow Power
<u>m3 / min</u>	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 030.2

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.