COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

1	Manufacturer: Atlas Copco		
	Manufacturer. Attas copeo		
	Model Number: ZT 110 VSD STD-8.6	Date:	01-18-2024
2	✓ Air-cooled	Type:	Screw
	☐ Lubricated ✓ Oil-free	# of Stages:	2
3	Full Load Operating Pressure*(b)	124.7	psig*(b)
4	Drive Motor Nominal Rating	147.5	hp
5	Drive Motor Nominal Efficiency	95.2	percent
6	Fan Motor Nominal Rating (if applicable)	8.0	hp
7	Fan Motor Nominal Efficiency	87.6	percent
8*	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	128.7 Max	634.0	20.3
	108.2	528.2	20.5
	88.7	422.4	21.0
	70.6	316.6	22.3
	54.0 Min	210.8	25.6
9*	Total Package Input Power at Zero Flow*(c,d)	17.5	kW
10	Specific Power (KW/100ACFM) 120 100 200 300 Car	400 500 60 Dacity (ACFM)	00 700

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Notes:

Member

Compressed Air & Gas Institute

- Measured at the discharge terminal point of the compressor package in accordance with
- ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Volume Flow Rate Specific Energy No Load / Zero Volume Flow Rate at specified conditions Consumption Flow Power $\underline{m3\ /\ min}$ ft3 / min % % Below 0.5 Below 15 +/- 7 +/- 8 0.5 to 1.5 15 to 50 +/- 6 +/- 7 +/- 10 +/- 5 +/- 6 1.5 to 15 50 to 500 +/- 4 +/- 5 Above 15 Above 500

ROT 031.2 12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.