

**COMPRESSOR DATA SHEET**

**In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors**

**Rotary Compressor: Fixed Speed**

| <b>MODEL DATA - FOR COMPRESSED AIR</b> |  |                  |                |
|--|--|------------------|----------------|
| 1                                      | Manufacturer: Atlas Copco  |                  |                |
| 2                                      | Model Number: G132-7.5   | Date: 05-15-2024 |                |
|  | <input checked="" type="checkbox"/> Air-cooled <input type="checkbox"/> Water-cooled | Type: Screw      |                |
|  |  | # of Stages: 1   |                |
| 3*                                     | Rated Capacity at Full Load Operating Pressure*(a,e)                                 | 839.5            | (acfm) *(a,e)  |
| 4*                                     | Full Load Operating Pressure*(b)   | 108.8            | psig*(b)       |
| 5                                      | Maximum Full Flow Operating Pressure*(c)   | 108.8            | psig*(c)       |
| 6                                      | Drive Motor Nominal Rating   | 177.0            | hp             |
| 7                                      | Drive Motor Nominal Efficiency   | 95.4             | percent        |
| 8                                      | Fan Motor Nominal Rating (if applicable)   | 4.0              | hp             |
| 9                                      | Fan Motor Nominal Efficiency   | 89.5             | percent        |
| 10*                                    | Total Package Input Power at Zero Flow*(e)   | 37.4             | kW*(e)         |
| 11                                     | Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)     | 154.5            | kW*(d)         |
| 12*                                    | Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e)  | 18.4             | kW/100 cfm*(e) |
| 13                                     | Isentropic Efficiency  | 75.6             | Percent        |

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program: [www.cagi.org](http://www.cagi.org)

- Notes:
- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
  - Member
  - b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
  - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
  - d. Total package input power at other than reported operating points will vary with control strategy.
  - e. Tolerance is specified in ISO 1217, Annex E, as shown in table below:  
NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



| Volume Flow Rate at specified conditions |                             | Volume Flow Rate | Specific Energy Consumption | No Load / Zero Flow Power |
|--|-----------------------------|------------------|-----------------------------|---------------------------|
| <u>m<sup>3</sup> / min</u>               | <u>ft<sup>3</sup> / min</u> | %                | %                           |                           |
| Below 0.5                                | Below 15                    | +/- 7            | +/- 8                       | +/- 10                    |
| 0.5 to 1.5                               |                             | +/- 6            | +/- 7                       |                           |
| 1.5 to 15                                | 50 to 500                   | +/- 5            | +/- 6                       |                           |
| Above 15                                 | Above 500                   | +/- 4            | +/- 5                       |                           |
|  |                             |                  |                             |                           |

ROT 030.1

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.