COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FO			
1	Manufacturer: Atlas Copco			
	Model Number: ZR 132 VSD-12	25	Date:	12-14-2018
2	Air-cooled x Water-cool	Type:	Screw	
	Oil-injected x Oil-free		# of Stages:	2
3	Rated Operating Pressure		100	psig ^b
4	Drive Motor Nominal Rating	Drive Motor Nominal Rating		hp
5	Drive Motor Nominal Efficiency		93.3	percent
6	Fan Motor Nominal Rating (if applicable)		-	hp
7	Fan Motor Nominal Efficiency		-	percent
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
	150.0	Max	792	18.9
0*	124.0		662	18.7
8*	99.0		532	18.6
	75.2		403	18.7
	52.7		273	19.3
9*	Total Package Input Power at Zero Flow	v ^{c, u}	13.5	kW
	35.0			
	30.0			
10	W) at			
	Specific Power (RW/100 A CFM) 20.0			
	Specifi W/J 00			
	15.0			
	0 50 100 150 200 250 30	00 350 400 4	450 500 550 600 650 700	750 800 850 900
	Note: Y-Axis Scale, 10 to 3	35, + 5kW/100ac	CFM) station of the data in Section 8 fm increments if necessary above 3: r maximum capacity	5

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Mombor

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy lume Flow Rate Consumption	
m ³ /min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8]
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

10/11 R7 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.