COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOR CO			
1	Manufacturer: Atlas Copco			
2	Model Number: ZR 132 VSD-125	Date:	12-14-2018	
	Air-cooled x Water-cooled	Type:	Screw	
	Oil-injected x Oil-free	# of Stages:	2	
3	Rated Operating Pressure	125	psig ^b	
4	Drive Motor Nominal Rating	177	hp	
5	Drive Motor Nominal Efficiency	93.3	percent	
6	Fan Motor Nominal Rating (if applicable)	-	hp	
7	Fan Motor Nominal Efficiency -		percent	
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	150.0 Ma	x 727	20.6	
0.4	126.0	613	20.6	
8*	102.7	499	20.6	
	80.4	386	20.8	
	59.0 M	n 272	21.7	
9*	Total Package Input Power at Zero Flow ^{c, d}	13.5	kW	
	35.0			
10	30.0			
	Specific Power Spec			
	Specification (KW)10			
	15.0			
	10.0 0 50 100 150 200 250 300 350 40 Capacity Note: Graph is only a visual repr Note: Y-Axis Scale, 10 to 35, + 5kW/10 X-Axis Scale, 0 to 25%	sentation of the data in Section 8 Oacfm increments if necessary above		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Mombor

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ /min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8]
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.