## COMPRESSOR DATA SHEET

**Rotary Compressor: Variable Frequency Drive** 

	MODEL DATA - FOR			
1	Manufacturer: Atlas Copco			
2	Model Number: ZR 160 VSD-125		Date:	12-17-2018
	Air-cooled x Water-cooled	Type:	Screw	
	Oil-injected x Oil-free		# of Stages:	2
3	Rated Operating Pressure		125	psig <sup>b</sup>
4	Drive Motor Nominal Rating		215	hp
5	Drive Motor Nominal Efficiency		93.3	percent
6	Fan Motor Nominal Rating (if applicable)		-	hp
7	Fan Motor Nominal Efficiency		-	percent
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>
	178.0	Max	843	21.1
0*	146.4		700	20.9
8*	116.2		557	20.9
	87.3		414	21.1
	59.9	Min	272	22.0
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>		13.5	kW
10	35.0			
	Specific Power (KW/100 A CFN)  20.0  20.0			
	\$\frac{\frac{1}{3}}{3} \frac{20.0}{3}			
	15.0			
	Co Note: Graph is only a visu Note: Y-Axis Scale, 10 to 35, +	apacity (AC al represen 5kW/100ac	0 550 600 650 700 750 800 8  CFM)  tation of the data in Section 8 im increments if necessary above 3 imaximum capacity	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>

NOTES:

Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> /min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	]
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

10/11 R7 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.