## COMPRESSOR DATA SHEET

**Rotary Compressor: Variable Frequency Drive** 

	MODEL DATA - FOR	COM	PRESSED AIR	
1	Manufacturer: Atlas Copco			
2	Model Number: ZR 315 VSD-150		Date:	12-17-2018
	Air-cooled x Water-cooled	Type:	Screw	
	Oil-injected x Oil-free		# of Stages:	2
3	Rated Operating Pressure		150	psig <sup>b</sup>
4	Drive Motor Nominal Rating		335	hp
5	Drive Motor Nominal Efficiency		95.3	percent
6	Fan Motor Nominal Rating (if applicable)		-	hp
7	Fan Motor Nominal Efficiency -		-	percent
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>
	316.1	Max	1478	21.4
0*	271.7		1279	21.2
8*	230.3		1080	21.3
	191.3	881	21.7	
	154.7 Mir		682	22.7
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>		24.2	kW
10	35.0 30.0 30.0 25.0 15.0 10.0 20.0 30.0 15.0 10.0 20.0 30.0 400 500 600 70 C.	00 800 9	00 1000 1100 1200 1300 1400 1: OFM) tation of the data in Section 8	500 1600 1700 1800

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m³/min	ft3 / min	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

10/11 R7 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.