## **COMPRESSOR DATA SHEET**

**Rotary Compressor: Variable Frequency Drive** 

		ory Compressor: Var ODEL DATA - FOR			
1	Manufacturer:	Atlas Copco			
	Model Number:	ZR 315 VSD-125		Date:	12-17-2018
2	Air-cooled x Water-cooled			Type:	Screw
	Oil-injected	x Oil-free		# of Stages:	2
3	Rated Operating Pr	ressure		100	psig <sup>b</sup>
4	Drive Motor Nominal Rating		335	hp	
5	Drive Motor Nominal Efficiency		95.3	percent	
6	Fan Motor Nominal Rating (if applicable)		-	hp	
7	Fan Motor Nomina	l Efficiency	-		percent
	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>
	334.7 N		Max	1759	19.0
	263.6			1448	18.2
8*	203.1		1136	17.9	
	149.2		825	18.1	
	100.6		Min	514	19.6
9*	Total Package Inpu	t Power at Zero Flow <sup>c, d</sup>		20.8	kW
10	35.0 30.0 30.0 30.0 Specific Power 25.0 30.0 30.0 30.0 30.0 30.0 30.0 30.0 3	_	acity (AC		1700 1800 1900 2000

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with

- ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}^3 / \mathbf{min}}$	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	]
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

10/11 R7 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.